



DEPARTMENT OF TRANSPORTATION
Fresno Area Express ♦ Fleet ♦ Handy Ride

**ADDENDUM NO. 6
FACILITY UPGRADE PROJECT
Bid File 3839**

NOTICE TO ALL BIDDERS

This Addendum is attached to and made a part of the above entitled specifications for the City of Fresno with a scheduled bid opening of 3:00 P.M. February 1, 2022.

All changes and or clarifications will appear in **bold underlined type.**

The attached documents have been made part of the specification:

1. **The Bid Opening Date has Changed to February 8, 2022.**

2. **Questions are extended through February 1, 2022, 5:00 PM.**

3. **Refer to attached RFI Questions and Answers.**

➤ END OF ADDENDUM NO. 6

CITY OF FRESNO

BRIAN CETTI
Capital Development Specialist

The bidder shall sign below indicating he/she has thoroughly read and understands the contents of this Addendum.

Signed: _____
Albert M. Giacomazzi - President
Company: AMG & Associates, Inc.

This addendum is being distributed ONLINE only and will not be sent by U.S. Mail. The bidder shall submit a signed copy of this addendum with their bid.

Addenda to date: 6



DEPARTMENT OF TRANSPORTATION
Fresno Area Express ♦ Fleet ♦ Handy Ride

The following questions have been received for 3839 – FAX Bus Wash Facility Upgrade Project.

- Regarding the bus wash, the plans referenced the specification for equipment but there were no equipment specs available in the original documents. Refer to response to pre-bid question #5.
- Is the contractor getting the permits or FAX? No FAX will be paying for permits
- Is there a phasing plan? This will be determined by the contractor and approved by FAX
- Can you clarify the differences between Bid Item No. 20 and Bid Item No. 22? Bid Item 22 is specifically for the complete new washing equipment system and installation; Bid Item 20 is for all other work delineated and associated for the existing bus wash facility.
- Is the EMS system to connect to Citywide EMS system? EMS does not connect to Citywide EMS.
- Does GC have to pay for water/elect service on site? Water service yes, Electrical no
- Would GC be able to use a temp office trailer on site? Yes
- Is GC responsible to provide a temp trailer for inspector/architect? No
- Do you anticipate a bid extension with the addendums coming out? No

-Jiah Hong, Stantec 1/26/2022

The Glass Shop Commercial

2005 E. Main Street • Visalia, CA 93292-6740

Contractor's No. 879788

(559) 732-5986 • (559) 334-0030 - Fax

www.theglassshop.com

RFI

DATE: 01-24-2022

TO: AMG

JOB: FRESNO AREA EXPRESS FACILITY IMPROVEMENTS

JOB LOCATION: 2223 "G" STREET FRESNO, CA. 93706

After looking at the plans

What I am looking for:

Spec section 08-51-13-1 aluminum windows call out more of a thermally broken fixed "window" from a storefront manufacturer, doesn't call out a specific model of window. We were going to go in with 8400TL Kawneer window if this is acceptable. The details on plan A-611 show more of a thermally broken storefront system which would be more like a 451T from Kawneer. On detail #11 it states, "inside set thermally broken aluminum window frame" and shows a storefront. Please clarify what direction you would like us to go an aluminum window or aluminum storefront.

On detail #1 and #2 on plan A-500 states a glass block, but there is no reference to this in the specs, window schedule or on the floor plans, we want to make sure we are not missing anything or if this scope will be handled by others. Please provide more details on this window/ locations or model/ type.

Please provide factory finish "color" for aluminum system on Plan A-610 window schedule, window "W1" states PT-2 painted finish which references dark bronze, this is offered in a anodized finish in lieu of paint and is cheaper than a painted finish. Please clarify finishes on all windows and if the dark bronze anodized is acceptable on "W1"?

1. Aluminum windows are to be used; verify that windows meet the standards in the Specifications.
2. Glass unit masonry is called out on the building elevations (A-241 and A-242). Refer to Spec Section 04 23 00 Glass Unit Masonry within the Technical Specifications.
3. Design intent for window W-1 is to match finish of adjacent door frame. W1 to be painted as specified in Drawings.

- Jiah Hong, Stantec 1/25/2022